

Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association, "Organization" (§633.026)

Informal Interpretation

Date: 1/4/2019

NFPA Document Number: NFPA 13R Edition: 2013

Paragraph Reference: A.5.2.3

Question (should be worded so that it can be answered with either "Yes" or "No"):

Does chemical resistance testing from 2004 showing product compatibility with CPVC piping together

with information from the CPVC manufacturer showing product containing the exact same concentation
of the active chemical as an approved chemical satisfy the "necessary consideration of chemical compatibility"
requirement contained in A.5.2.3 of the NFPA document referenced above? See Exhibit A for specific

details on the exact evidentiary documents provided to LFO.

Answer: No

In accordance with NFPA 13R section 5.2.3.1.1.1 and 5.2.3.1.2, nonmetallic piping shall be installed in accordance with the manufacture's installation instructions and listing limitations. The manufacture's installation instructions and listing limitations should include specific direction regarding product compatibility. The LFO's approval of product compatibility, and compliance with NFPA 13R, should be derived from the specific product approval direction provided by the CPVC product manufacture. The resolution to this issue is for the CPVC product manufacturer to render an opinion on the approval of the use of the specific product in this application. The product manufacturer must approve the compatibility of this specific product in this application in order for the LFO to ensure compliance with NFPA 13R and the Florida Fire Prevention Code.

Note: The FCIC recognizes that their maybe a delay in approval of a new product by the manufacture. Therefore, options could be explored with the LFO, Tim-Bor, General Contractor and other parties to allow a CO to be issued while manufacturer approval of this specific product take place. As an example, the following conditions could be implemented to allow CO to be issued with the LFO approval:

1. Tim-Bor has completed an application for product approval with Spears and Spears has confirmed receipt of the product approval submittal and;

Rulings herein expressed are not the formal position of the Florida State Fire Marshal's Office

Florida Fire Marshals and Inspectors Association | P. O. Box 325 Hobe Sound, FL 33475 | Tel 772-349-1507 | Fax 772-546-6675



Florida Division of State Fire Marshal

The Florida Fire Marshals and Inspectors Association, "Organization" (§633.026)

- 2. A signed and sealed opinion has rendered by Florida Registered Professional Engineer that the Tim-Bor product is identical to other approved Spears approved products, the application is similar and compatibility with the CPVC would be acceptable and;
- 3. A surety bond has been issued to ensure that if the Tim-Bor product is not approved by Spears within X time, the CPVC will be replaced and all associated repairs conducted.

The above items are just examples and other equivalent options could be explored to ensure product approval or, if product approval is not forthcoming, eventual replacement and repair with code compliant products.

Committee Answer Submitted by, James Groff, Chairman Informal Fire Code Interpretation Committee

Region 1: Vacant / Vacant

Region 2: Babette Ferris-No response / Vacant Region 3: James Groff-No / Robert Growick-No

Region 4: Philip Guglietti-No / Vacant

Region 5: Anthony Apfelbeck –No/ Timothy Ippolito No

Region 6: Robert Salvaggio-No/Alternate Kathy Szostak-No Response

Region 7: Bryan Parks-No response / Alternate Janet Washburn-No

Committee Region Map

Rulings herein expressed are not the formal position of the Florida State Fire Marshal's Office

Florida Fire Marshals and Inspectors Association | P. O. Box 325 Hobe Sound, FL 33475 | Tel 772-349-1507 | Fax 772-546-6675