



Florida Fire Marshals And Inspectors Association

Informal Interpretation

Date: June 14, 2010

NFPA Document Number: 101/FPC 2007

Edition: 2007

Paragraph Reference: FPC Para: 7.2.5.3.1(3)

If this involves an actual situation, explain briefly:

Permit pending of a proposed project

Question (*should be worded so that it can be answered with either "Yes" or "No"*):

Can a combustible egress ramp be terminated at 30" AFF and continued (same ramp) with a NON combustible ramp structure to levels above 30" AFF.

Answer:

No.

The basis for the reply as offered is that once a ramp crosses the 30" threshold the entire ramp needs to meet the more restrictive requirements of the non-combustible construction type.

Committee Answer Submitted by,

Bart Wright, Chair
Informal Fire Code Interpretation Committee